



| Nr | Name | Description |
|----|----------------------------------|----------------------------|
| 1 | Liquid pipe connection | ø 6.35 flare (connection) |
| 2 | Gas pipe connection | ø 12.70 (flare connection) |
| 3 | Drain pipe connection | VP25 (O.D. ø 32 I.D. ø 25) |
| 4 | Remote control wiring connection | |
| 5 | Power supply connection | |
| 6 | Drain hole | VP25 (OD ø 32 I.D. ø 25) |
| 7 | Air filter | |
| 8 | Air suction side | |
| 9 | Air discharge side | |
| 10 | Nameplate | |

NOTE

- 1 Refer to 'outlook drawing for installing optional accessories' when installing optional accessories.
- 2 The required ceiling depth varies according to the configuration of the specific system.
- 3 For maintenance of the air filter, it is necessary to provide a service access panel. Refer to the 'filter installation method' drawing.