



Nr	Part name	Description
1	Liquid pipe connection	$\varnothing 9.5$ flare connection
2	Gas pipe connection	$\varnothing 15.9$ flare connection
3	Drain pipe connection	VP25 (O.D. $\varnothing 32$, I.D. $\varnothing 25$)
4	Ground terminal	M4
5	Switch box	
6	Interunit wiring connection	
7	Power supply connection	
8	Air discharge flange	
9	Air suction flange	
10	Hook	For M8~M10

NOTES

- 1 Location of unit's name plate: switch box surface.
- 2 Mount the air filter at the suction side. (Select its colorimethod (gravity method) 50% or more).
- 3 Be sure to install a drain trap, as the drain outlet of the air-conditioner becomes negative pressure.
- 4 Be sure to install a drain trap for each unit separately, when you install a consolidated drain piping.